



January 6, 2011

MANUFACTURED HOUSING ENTERPRISES
JOHN H. BAILEY
09302 STATE ROUTE 6
BRYAN OH 43506

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: MANUFACTURED HOUSING ENTERPRISES
Product Name: THE WINDSOR
Model Number(s): M48B02
Product File No: 20110009

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2016.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 38 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.

This approval supersedes the approval issued on January 20, 2006 under product file number 20050934.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050934

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov